



Seveso Safety Case on Ammonium Nitrate Storage

Pat Cosgrove


Irish Industrial Explosives



Irish Industrial Explosives

- Operating in Ireland since 1967
- Provides full range of commercial explosive products
- Manufactures catridged emulsions, bulk emulsions and ANFO
- Top tier Seveso site
- Located in rural area













Introduction

- Ammonium Nitrate – storage is carried out at all explosives manufacturing plants
 - At IIE limit of storage is 1500 tons, in practice 1200 tons stored
 - Stored on a concrete pad with a steel clad roof and partial steel clad sides
 - Pad is located more than 100m from manufacturing plants and explosives storage
-



Hazardous Properties of Ammonium Nitrate

- Ammonium Nitrate is an oxidiser – capable of detonation if
 - Heated under confinement
 - Contaminated with carbonaceous materials will increase sensitivity to detonation
- Ammonium Nitrate will release toxic fumes if heated to decomposition - these are mainly oxides of Nitrogen – NO and NO₂ and NH₃.



Hazard Identification

- 3 main sources used
 - NFPA 490 - Code for the Storage of Ammonium Nitrate 1998 edition.
 - UK HSE - Storage and Handling of Ammonium Nitrate
 - Factory Mutual - FM Global Property Loss Prevention Data Sheet no. 7-89. Revised Sept 2000.
 - The main hazards were extracted from the above study and then 2 scenarios selected for further examination. These scenarios were
 - Detonation from a fire in AN pad due to maintenance / hot work
 - Toxic Gas Release
 - Fire in AN pad due to a forklift fire
 - Fire in adjacent forklift / spare parts store and spread.
-



Consequence Assessment

- To detonate 3 conditions are generally required to be met
 - Contamination
 - Major source of initiation (eg fire or some other significant source of heat)
 - Confinement
 - However in this safety case the detonation can be caused by a strong initiation source
 - A stack of 173 tons was used as the basis for the assessment – 2m H x 3m W x 32 bags length
 - The TNT equivalence method was used – based on FM and HSE guidelines 57 tons of TNT was quantity used
-



Overpressure Effects


Distance	Overpressure (mbar)	Description of damage
• 50m	10000	Total destruction
• 100m	1700	Total destruction
• 200m	430	Nearly complete destruction of houses.
• 300m	200	Steel frame building distorted and pulled away from foundations. >50% destruction of brick work of houses.
• 400m	125	Corrugated steel panels fastenings fail.
• 500m	110	Steel frame of clad building partially distorted. Houses – moderate damage.
• 600m	70	Windows shattered. Possible damage to window frames.

Points of Interest

• 846m	50 mbar	Onset of irreversible effects.
• 1290m	30 mbar	Specified area end point.
• 385m	140 mbar	First deaths LC1%
• 145m	900 mbar	Nearest magazine (M11)



Explosion Overpressure Plot





Fire Modelling

- AN fires are difficult to model
 - Rate of decomposition variability
 - Ratio of gases released (NO v NO₂)
 - Buoyancy of the gas plume and for warehouses gas movement effects
- Using results from HSE experiments
 - A forklift fire is simulated
 - A fire in nearby stores



Forklift Fire

- NO_2 produced from:
 - Thermal radiation emitted from the fire
 - Contact between the fire and the AN

Energy released by forklift fire is a maximum of 3000kW for 30 mins worst case

AN decomposition rate in worst case scenario is 150 g/s/m²

NO_2 release from thermal radiation = 0.1073 kg/s

NO_2 release from contact reactions = 0.1000 kg/s

Using the ADMS – suited to modelling buoyant releases:



Dispersion Modelling

Weather Class	ERPG2 (15ppm)	ERPG1 (1 ppm)	DTL (56.5ppm)	1/2DTL (28.8ppm)
F 1.5m/s	0 m	16.7m	0 m	0 m
D 5 m/s	83.3 m	>500 m	0 m	50 m
D 10 m/s	66.7 m	400 m	0 m	50 m

Based on this data the thermal radiation event is a serious event



Fire in nearby Stores

- Model of effect of thermal radiation in nearby parts store (10m separation)
- Heat transfer calculations:
 - Temp of fire 1100C, emmissivity = 0.9
 - 16kW/m² results in decomp rate of 1 g/m²/s
 - Based on exposed area of AN the NO₂ production rate is 0.0093 kg/s
 - Lower than the previous values for a forklift fire

This fire event is categorised as a serious incident



Frequency Analysis

- Estimate of fire rate for fork trucks
 - Use HGVs accident statistics as data
 - 221×10^8 km/yr by HGV = 50,800km/yr
 - Crashes are 2578, 19 crash fires
 - 0.1166×10^{-6} fires/km
 - 5.9×10^{-3} fires/yr per HGV

Assumed forklift has similar rate to that of HGV
- Fire in nearby store – use BS7974
 - Gives probability of a fire 0.0352/yr (1 in 28.3yrs)



Ammonium Nitrate Pad – Frequency Rating

Scenario	Consequence	Protective Measures	Frequency Rating
Internal fire due to maintenance, hot work leading to a fire and/or detonation	Fire with toxic gas release	Rare to do hot work, permits system in place, fire detection system, no combustible materials present	Hot work = 0.2/yr. Hot work permit failure = 0.001 Fire response failure = 0.4 Fire spread = 0.01 Total = $0.8 \times 10^{-6}/\text{yr}$ (1 in 1,250,000 yrs) Detonation / Fire ratio = 0.1
	Explosion with equivalence to 57 ton of TNT ie 1 stack	Significant probability that fire will not lead to detonation (1 in 10 chance)	Total = $0.8 \times 10^{-7} \text{ yr}$ (1 in 12,500,000 yrs)
Internal fire due to Forklift fire	Fire with toxic gas release	Low frequency of forklifts in area, Driver always present, fire extinguishers present, fire detection system in place	Basic forklift fire = $5.9 \times 10^{-3} / \text{yr}$ Forklift present = 0.024, Driver does not extinguish fire = 0.7 Fire response failure = 0.4 Total = $3.96 \times 10^{-5} / \text{yr}$ (1 in 25,222 yrs) Detonation / Fire ratio = 0.1 Fire spread = 0.01
	Explosion with equivalence to 57 ton of TNT ie 1 stack	Significant probability that fire will not lead to detonation (1 in 10 chance)	Total = $3.96 \times 10^{-8} \text{ yr}$ (1 in 25,222,000 yrs)
External fire in forklift/spare parts store	Fire with toxic gas release	No ignition sources present, fire wall between store and pad, fire detection system, no combustible materials present	Basic estimation = $3.52 \times 10^{-2} / \text{yr}$, Fire response failure = 0.4 Concrete wall = 0.01 Total = $1.41 \times 10^{-4} / \text{yr}$ (1 in 7102 yrs)
	Explosion with equivalence to 57 ton of TNT ie 1 stack	Significant probability that fire will not lead to detonation (1 in 10 chance)	Detonation / Fire ratio = 0.1 Fire Spread = 0.01 Total = $1.41 \times 10^{-7} \text{ yr}$ (1 in 7,102,000 yrs)